

PAT Report Certificate

Client Details

Company Name: Nexus Institute of Creative Arts
 Address: Astoria House
 71 Albany Road
 Earlsdon
 Coventry
 CV5 6JR

PATTCO



Details of Contractor Responsible for Testing

Company Name: PATTCO Ltd Telephone: 0800 085 0482
 Address: The Buckman Building Fax: 01425 462530
 43 Southampton Road Ringwood Hants BH24 1HE Email: sales@pattco.co.uk

Job Details

Start Date: 17/12/2018 Job No.: NEXUS 72969
 Total Qty of Items: 623

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
 (or test not applicable)

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
-----------	----------------	------------	--------	------------------	-----------------------	------	---------------	---------------	------------	-------------	-------

The Following Items FAIL

DRUM ROOM

7101447	AMPLIFIER	LINE 6	F	0 Ω - (S)	0 MΩ - (S)	S	S	S	FAIL	17/12/2018	BROKEN CONNECTOR
---------	-----------	--------	---	-----------	------------	---	---	---	------	------------	------------------

STAGE

7101455	STAGE LIGHT	UNKNOWN	F	0 Ω - (S)	0 MΩ - (S)	S	S	S	FAIL	17/12/2018	EXPOSED WIRES
7101454	STAGE LIGHT	UNKNOWN	F	0 Ω - (S)	0 MΩ - (S)	S	S	S	FAIL	17/12/2018	EXPOSED WIRES
7101453	STAGE LIGHT	UNKNOWN	F	0 Ω - (S)	0 MΩ - (S)	S	S	S	FAIL	17/12/2018	EXPOSED WIRES
7101452	STAGE LIGHT	UNKNOWN	F	0 Ω - (S)	0 MΩ - (S)	S	S	S	FAIL	17/12/2018	EXPOSED WIRES
7101451	STAGE LIGHT	UNKNOWN	F	0 Ω - (S)	0 MΩ - (S)	S	S	S	FAIL	17/12/2018	EXPOSED WIRES
7101450	STAGE LIGHT	UNKNOWN	F	0 Ω - (S)	0 MΩ - (S)	S	S	S	FAIL	17/12/2018	EXPOSED WIRES

VOCAL ROOM

7101449	EXTENSION	LEAD	F	0 Ω - (S)	0 MΩ - (S)	S	S	S	FAIL	17/12/2018	CASE DAMAGE
7101448	AMPLIFIER	LINE 6	F	0 Ω - (S)	0 MΩ - (S)	S	S	S	FAIL	17/12/2018	BROKEN CONNECTOR

End of items that FAIL

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)

Label No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	PASS FAIL	Date Tested	Notes
-----------	----------------	------------	--------	------------------	-----------------------	------	---------------	---------------	-----------	-------------	-------

The Following Items PASS

BASS ROOM

7101095	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101093	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101091	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101090	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101089	KEYBOARD	MOOG	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101088	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101087	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101086	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101096	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101084	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101094	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101085	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101102	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101097	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101107	FAN	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101106	TELEVISION	LG	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101105	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101092	AMPLIFIER	MARSHALL	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101103	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101101	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101100	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101099	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101098	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101104	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

CLEANERS CUPB'D

7100983	VACUUM	NUMATIC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100979	VACUUM	NUMATIC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100978	VACUUM	NUMATIC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100980	VACUUM	NUMATIC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100982	VACUUM	NUMATIC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100981	VACUUM	NUMATIC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

DRUM ROOM

7101068	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101065	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101058	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101059	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101060	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101061	AMPLIFIER	UNKNOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101062	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101064	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101066	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101067	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101083	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101063	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
7101069	TELEVISION	LG	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101078	AMPLIFIER	ASHDOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101079	AMPLIFIER	PEAVEY	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101080	AMPLIFIER	PEAVEY	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101082	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101077	AMPLIFIER	ASHDOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101076	AMPLIFIER	MARSHALL	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101072	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101074	AMPLIFIER	LANEY	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101070	APPLE TV	APPLE	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101071	FAN	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101073	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101075	AMPLIFIER	LANEY	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101081	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	

GUITAR ROOM

7100998	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100997	APPLE TV	APPLE	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100996	TELEVISION	TECHNIKA	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100995	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100994	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100993	AMPLIFIER	BLACKSTAR	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100992	AMPLIFIER	BLACKSTAR	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101024	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100990	AMPLIFIER	VALVEKING	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100989	AMPLIFIER	VALVEKING	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100999	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101005	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100984	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100985	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100986	AMPLIFIER	ASHDOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100987	AMPLIFIER	LINE 6	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100988	AMPLIFIER	MARSHALL	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101023	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101012	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100991	AMPLIFIER	LINE 6	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101021	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101020	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101019	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101018	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101017	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101016	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101015	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101003	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101013	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101000	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101022	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101011	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101010	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
7101009	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101008	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101007	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101006	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101004	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101002	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101001	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101014	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

KEYS ROOM

7101049	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101041	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101057	TELEVISION	LG	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101056	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101055	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101054	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101053	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101052	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101051	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101050	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101038	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101048	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101046	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101045	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101044	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101047	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101033	FAN	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101026	KEYBOARD	NORD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101027	KEYBOARD	NORD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101028	KEYBOARD	NORD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101029	KEYBOARD	YAMAHA	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101030	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101043	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101032	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101042	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101034	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101035	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101036	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101037	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101039	APPLE TV	APPLE	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101025	KEYBOARD	NORD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101031	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101040	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

KITCHEN

7101427	COFFEE M/C	BRAVILOR	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101420	WTR BOILER	SWAN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101428	KETTLE BASE	IGENIX	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101426	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
7101425	DISHWASHER	HOTPOINT	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101424	WTR BOILER	BUFFALO	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101423	TOASTER	RUSSELL HOBBS	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101422	MICROWAVE	IGENIX	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	Emission Level (mW/CM2 at 5CM) - 0.2
7101421	MICROWAVE	IGENIX	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	Emission Level (mW/CM2 at 5CM) - 0.2
7101429	KETTLE	IGENIX	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
LIBRARY											
7101169	MONITOR	CTX	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101168	LAMP	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101167	LAMP	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
LIVE ROOM											
7100914	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100921	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100924	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100923	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100922	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100911	AMPLIFIER	MARSHALL	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100910	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100909	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100920	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100919	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100918	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100917	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100915	CD PLAYER	HHB	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100913	AMPLIFIER	LINE 6	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100912	AMPLIFIER	ASHDOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100916	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
MAC ROOM											
7101114	IMAC	APPLE	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101109	IMAC	APPLE	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101123	AMPLIFIER	BLACKSTAR	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101135	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101134	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101133	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101132	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101131	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101130	EXTENSION	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101129	AIR CON	CHIGO	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101128	TELEVISION	HITACHI	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101127	SPEAKER	FOCAL	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101126	SPEAKER	FOCAL	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101112	IMAC	APPLE	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101124	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101110	IMAC	APPLE	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101122	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101121	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
7101120	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101119	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101118	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101117	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101116	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101115	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101108	IMAC	APPLE	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101113	IMAC	APPLE	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101111	IMAC	APPLE	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101125	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	

MAIN HALL

7101394	AV EQUIPMENT	UNKNOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101401	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101400	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101399	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101398	AV EQUIPMENT	UNKNOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101397	AV EQUIPMENT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101402	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101395	AV EQUIPMENT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101393	AV EQUIPMENT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101392	AV EQUIPMENT	UNKNOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101390	LAMP	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101389	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101388	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101387	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101419	FRIDGE	MINI	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101396	AV EQUIPMENT	UNKNOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101413	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101391	MONITOR	SAMSUNG	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101418	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101403	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101417	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101416	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101415	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101414	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101412	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101411	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101407	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101404	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101405	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101406	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101408	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101409	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101410	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

MEETING ROOM

7101441	HEATER	UNKNOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101440	TIMER	UNKNOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
-----------	----------------	------------	--------	------------------	-----------------------	------	---------------	---------------	------------	-------------	-------

PRACTICE ROOM

7100927	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100925	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100926	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

RECEPTION

7100855	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100850	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100839	MONITOR	SAMSUNG	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100834	COMPUTER	LENOVO	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100835	COMPUTER	LENOVO	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100836	MONITOR	SONY	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100837	MONITOR	OPTIQUEST	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100838	MONITOR	DELL	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100854	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100840	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100841	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100842	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100843	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100844	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100845	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100846	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100847	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100849	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100851	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100833	COMPUTER	LENOVO	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100862	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100852	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100848	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100856	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100857	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100858	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100859	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100861	TELEVISION	TOSHIBA	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100860	SHREDDER	BONSAIL	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100853	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	

SIDE RECEPTION

7100873	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100872	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100871	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100870	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100869	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100874	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100864	COMPUTER	LENOVO	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100878	FAN HEATER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100865	MONITOR	AOC	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100868	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100875	SHREDDER	REXEL	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
7100866	MONITOR	HP	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100877	LAMP	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100879	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100880	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100881	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100882	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100883	FAN HEATER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100863	COMPUTER	LENOVO	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100867	MONITOR	ATEC	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100876	LAMP	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
STAFF ROOM											
7101173	EXTENSION	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101182	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101192	CIRCULAR SAW	BOSCH	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101191	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101190	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101189	LIGHTS	FAIRY	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101188	LIGHTS	FAIRY	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101187	LIGHTS	FAIRY	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101186	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101185	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101171	PRINTER	HP	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101183	LAMP	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101170	TELEVISION	ELECTRIQ	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101181	COFFEE M/C	BOSCH	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101180	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101179	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101178	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101177	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101176	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101175	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101174	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101172	SERVER	UNKNOWN	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101184	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
STAGE											
7101197	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101327	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101291	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101317	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101318	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101319	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101320	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101321	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101322	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101323	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101324	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101315	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	

Appliance Details and Test Results

**Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)**

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
7101326	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101314	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101328	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101329	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101330	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101331	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101332	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101333	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101334	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101335	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101336	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101337	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101325	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101303	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101292	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101293	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101294	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101295	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101296	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101193	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101298	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101195	PROJECTOR	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101300	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101316	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101302	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101340	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101304	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101305	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101306	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101307	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101308	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101309	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101310	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101311	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101312	EXTENSION	ADAPTOR	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101313	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101301	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101376	STAGE LIGHT	UNKNOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101365	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101366	STAGE LIGHT	UNKNOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101367	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101368	STAGE LIGHT	UNKNOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101369	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101370	STAGE LIGHT	UNKNOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101371	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101372	STAGE LIGHT	UNKNOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101373	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101338	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

Appliance Details and Test Results

**Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)**

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
7101375	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101362	STAGE LIGHT	UNKNOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101377	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101378	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101379	FAN	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101380	LAMP	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101381	STAGE LIGHT	UNKNOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101382	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101383	FOG MACHINE	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101384	FOG MACHINE	UNKNOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101385	FOG MACHINE	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101386	EXTENSION	REEL	P	0.17 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101374	STAGE LIGHT	UNKNOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101352	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101297	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101341	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101342	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101343	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101344	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101345	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101346	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101347	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101348	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101349	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101364	STAGE LIGHT	UNKNOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101351	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101363	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101353	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101354	MIXER	MOMARK	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101355	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101356	STAGE LIGHT	UNKNOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101357	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101358	STAGE LIGHT	UNKNOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101359	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101360	STAGE LIGHT	UNKNOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101361	STAGE LIGHT	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101339	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101350	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101231	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101242	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101221	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101222	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101223	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101224	MIXER	YAMAHA	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101225	LIGHT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101226	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101227	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101228	STAGE LIGHT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

Appliance Details and Test Results

**Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)**

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
7101219	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101230	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101218	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101232	LIGHT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101299	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101234	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101290	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101236	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101237	TELEVISION	SAMSUNG	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101238	TELEVISION	SAMSUNG	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101239	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101240	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101241	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101229	STAGE LIGHT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101207	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101194	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101196	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101198	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101199	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101200	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101201	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101202	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101203	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101204	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101220	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101206	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101235	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101208	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101209	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101210	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101211	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101212	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101213	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101214	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101215	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101216	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101217	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101205	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101279	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101268	AV EQUIPMENT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101269	AV EQUIPMENT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101270	AV EQUIPMENT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101271	AV EQUIPMENT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101272	AV EQUIPMENT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101273	AV EQUIPMENT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101243	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101275	LIGHT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101233	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
7101267	AV EQUIPMENT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101278	EXTENSION	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101274	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101280	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101281	AV EQUIPMENT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101282	AV EQUIPMENT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101283	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101284	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101285	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101286	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101287	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101288	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101289	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101277	EXTENSION	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101247	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101244	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101245	AMPLIFIER	UNKNOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101276	LIGHT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101246	AMPLIFIER	UNKNOWN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101266	AV EQUIPMENT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101248	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101249	MONITOR	LG	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101250	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101251	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101252	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101253	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101263	EXTENSION	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101254	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101264	EXTENSION	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101262	AV CABINET	UNKNOWN	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7101261	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101260	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101259	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101258	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101257	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101256	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101255	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101265	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
STORES											
7101431	KETTLE BASE	WILKO	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101438	SANDER	VONHAUS	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101446	BATT.CHARGER	BOSCH	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101445	HEAT GUN	BLACK & DECKE	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101444	SAW	EVOLUTION	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101443	VACUUM	NUMATIC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101442	VACUUM	NUMATIC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101439	BATT.CHARGER	DRAPER	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101437	DRILL	BOSCH	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
-----------	----------------	------------	--------	------------------	-----------------------	------	---------------	---------------	------------	-------------	-------

7101436	SANDER	BLACK & DECKE	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101435	DRILL	BLACK & DECKE	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101434	JIG SAW	BLACK & DECKE	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101432	KETTLE	WILKO	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101430	POPCORN M/C	UNKNOWN	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101433	SANDER	WICKES	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

STUDENT CANTEEN

7101145	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101148	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101143	MICROWAVE	COOKWORKS	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	Emission Level (mW/CM2 at 5CM) - 0.2
7101136	EXTENSION	ADAPTOR	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101137	FRIDGE	LG	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101138	TOASTER	COOKWORKS	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101139	KETTLE BASE	IGENIX	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101140	KETTLE	IGENIX	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101141	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101142	MICROWAVE	COOKWORKS	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	Emission Level (mW/CM2 at 5CM) - 0.2
7101144	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101147	LAMP	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101146	LAMP	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

STUDIO

7101161	MONITOR	HP	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101166	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101165	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101164	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101162	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101156	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101160	MAC	APPLE	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101159	SPEAKER	FOCAL	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101158	SPEAKER	FOCAL	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101155	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101157	AV EQUIPMENT	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101149	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101150	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101151	MAC MINI	APPLE	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101152	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7101153	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101154	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7101163	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	

THE HUB

7100894	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100893	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100892	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100891	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100890	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100889	UPS	APC	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
7100888	UPS	APC	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100885	SERVER	DELL	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100895	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100886	SERVER	NETGEAR	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100887	SERVER	WATCHGUARD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100906	EXTENSION	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100896	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100884	SERVER	HP	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100908	LAMINATOR	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100907	PRINTER	HP	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100905	EXTENSION	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100904	2 PIN	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100899	POWERSUPPLY	ACDC	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100897	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100898	IEC	LEAD	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100903	MONITOR	UNKNOWN	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100900	POWERSUPPLY	ACDC	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100901	POWERSUPPLY	ACDC	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	
7100902	APPLE TV	APPLE	P	0 Ω - (S)	0 MΩ - (S)	S	S	S	PASS	17/12/2018	

VOCAL ROOM

7100930	FAN	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100942	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100949	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100951	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100950	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100947	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100946	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100945	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100944	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100943	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100948	AMPLIFIER	PEAVEY	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100941	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100940	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100939	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100938	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100952	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100929	FAN	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100975	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100931	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100932	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100933	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100934	AMPLIFIER	PEAVEY	P	0.11 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100935	AMPLIFIER	ASHDOWN	P	0.08 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100936	AMPLIFIER	CARVIN	P	0.09 Ω - (P)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100928	FAN	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100968	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100937	MIXER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100957	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

Appliance Details and Test Results

Key: (P) = Pass / (F) = Fail / (S) = Skip
(or test not applicable)

Lable No.	Appliance Type	Serial No.	Visual	Earth Continuity	Insulation Resistance	Load	Earth Leakage	Lead Polarity	P ASS FAIL	Date Tested	Notes
7100958	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100959	SPEAKER	UNKNOWN	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100960	IEC	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100961	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100962	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100963	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100964	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100965	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100977	EXTENSION	LEAD	P	0.06 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100967	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100953	EXTENSION	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100969	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100970	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100971	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100972	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100973	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100974	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100976	IEC	LEAD	P	0.07 Ω - (P)	200 MΩ - (P)	S	S	P	PASS	17/12/2018	
7100956	TELEVISION	LG	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100955	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100954	2 PIN	LEAD	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	
7100966	POWERSUPPLY	ACDC	P	0 Ω - (S)	200 MΩ - (P)	S	S	S	PASS	17/12/2018	

End of items that PASS